

General Environmental Incident Summary

Incident: 4009 **Date/Time Notice:** 1/25/2016 1600 **DEM Incident No:**

Responsible Party: City of Grand Forks

Date Incident: 1/24/2016 **Time Incident:** 1115 **Duration:**

County: Grand Forks **Twp:** 151 **Rng:** 50 **Sec:** 6 **Qtr:**

Lat: 47.93000 **Long:** -97.10000 **Method:** Interpolation from map

Location Description: Approximately 7th Avenue North and N. 48th Street

Submitted By: Lisa Botnen

Affiliation: City of Grand Forks

Address: 724 N. 47th Street

City: Grand Forks

State: ND

Zip: 58203

Received By:

Contact Person: Pete Aamold
724 N. 47th Street
Grand Forks, ND 58203

Distance Nearest Occupied Building: 500 Feet

Release Contained: Yes

Type of Incident: Sewage Accident

Description of Released Contaminant: Domestic Sewage

Volume Spilled: 100000.00 gallons

Ag Related: No

EPA Extremely Hazardous Substance: No

Reported to NRC: Unknown

Cause of Incident:

Sewage line failed.

Risk Evaluation:

None.

of Fatalities: 0

of Injuries: 0

Affected Medium: 03 - soil

Potential Environmental Impacts:

Some waste may have soaked into the surrounding soil.

Action Taken or Planned:

The leak was located and isolated. City staff worked with the City's contract engineering firm and a local excavator to dig up and repair the affected line. Samples of the sewage were taken. Some sewage leaked into a nearby catch basin. The stormwater line had standing water in it, so the manholes in this area were pumped out with the vac truck.

Wastes Disposal Location: The City's Wastewater Treatment Plant.

Agencies Involved:

Updates

Date: 1/26/2016 ***Status:*** Reviewed - Assigned to NDDoH Division

Author: Crowdus, Kory

Updated Volume:

Notes:

Report forwarded to the Municipal Facilities Division.